

Cheri Sawyer

From: Shyam Sunder [sunder@nist.gov]
Sent: Thursday, September 16, 2004 2:26 PM
To: jason.averill@nist.gov
Cc: cauffman@nist.gov; cheri.sawyer@nist.gov; john.eichner@nist.gov
Subject: Fwd: RE: Questions for the Port Authority

>X-Sieve: CMU Sieve 2.2
>From: "Bhol, Saroj" <sbhol@panynj.gov>
>To: "'Shyam Sunder'" <sunder@nist.gov>
>Cc: "Begley, James" <jbegley@panynj.gov>,
> "Hurley, Michael"
> <mhurley@panynj.gov>, "Lin, C. John" <jlin@panynj.gov>,
> "Lombardi, Frank" <flombard@panynj.gov>,
> "Reiss, Alan"
> <areiss@panynj.gov>
>Subject: RE: Questions for the Port Authority
>Date: Thu, 16 Sep 2004 14:20:33 -0400
>X-Mailer: Internet Mail Service (5.5.2657.72)
>X-MailScanner:
>X-MailScanner-From: sbhol@panynj.gov
>
>Shyam,
>Here's the response to the information request:
>
>1. After the lease was signed by Silverstein, who conducted the fire
>drill training (i.e., Silverstein employees, Port Authority employees,
>or a transition team representing both)?
>
>After the lease was signed on July 24th, the initial fire safety
>training(i.e., when a tenant first occupied their space or initial fire
>safety team training) was conducted by PA transition team personnel
>from the WTC fire safety unit. Bi Annual fire drills for tenants were
>next scheduled to be conducted in the fall. None were conducted in the
>approximately 6 week period between the closing and the attack. Prior
>to the lease, PA staff held a small meeting/critique after each floor
>fire drill (a 5-10 minute gathering in the hallway) and would address concerns, answer
>questions, etc.
>Those meetings, pre July 24th, were conducted by PA personnel and a
>deputy fire safety director who was a contracted employee from OCS. The
>OCS Contract was assigned to Silverstein Properties upon closing. Pa
>was not aware of what Silverstein Properties plan was for conducting
>the required fire drills in the fall of 2001 and ongoing.
>
>2. Can you specify which floors in WTC 1 and WTC 2 were designated as
>re-entry?
>
>No. There were lists maintained at the fire command stations (among
>other places); however, it was to extensive to commit to memory.
>
>3. The emergency procedures manual cited a 3 day warning of an
>impending fire drill; a previous communication from Saroj cited a
>two-week written notice. Was practice somewhat longer than the written policy?
>
>Tenants would be given a minimum two week notice. Experience showed
>that advanced notices were appreciated by the tenants and allowed them
>to schedule their business activities accordingly - which in turn
>generally lead to more favorable participation at the drills.
>
>
>4. Our interpretation of the deputy floor warden is that they act as a
>back-up floor warden, and otherwise a searcher. Is this correct?

>
>Yes, basically.
>
>5. The floor warden training video indicates that the Fire Safety
>Director informs the floor warden which stairwell to use, while the
>emergency procedures manual says that the floor warden tells the Fire
>Safety director which stairwell the occupants are using. Is this
>simply a matter of each keeping the other informed?
>
>Yes. It actually depended on the situation. If the circumstances
>allowed the FCS to tell the floor warden which stairway to use, then
>they would be based on knowledge of where the fire was located, which
>stairways were being used by other floors, which stairway was being
>used by FDNY, etc. On the other hand, if the conditions on the floor
>did not permit the standard gathering of occupants in the corridor
>before the evacuation and the occupants needed to evacuate immediately,
>it would be desirable for the warden to tell the FCS which stairway they were using.
>
>Thanks
>
>Saroj
>
>-----Original Message-----
>From: Shyam Sunder [mailto:sunder@nist.gov]
>Sent: Monday, September 13, 2004 11:36 AM
>To: Bhol, Saroj
>Cc: jason.averill@nist.gov; cauffman@nist.gov; cheri.sawyer@nist.gov;
>john.eichner@nist.gov
>Subject: Fwd: Questions for the Port Authority
>
>
>Saroj,
>
>Could you please respond to the following information request? Thanks.
>
>Shyam
>
>=====

>
> >X-Sieve: CMU Sieve 2.2
> >From: "Jason D. Averill" <jason.averill@nist.gov>
> >To: "'Shyam Sunder'" <sunder@nist.gov>
> >Subject: Questions for the Port Authority
> >Date: Mon, 13 Sep 2004 11:33:17 -0400
> >X-Mailer: Microsoft Outlook, Build 10.0.6626
> >Importance: Normal
> >
> >Shyam,
> >
> >We have a couple of clarifying questions:
> >
> >1. After the lease was signed by Silverstein, who conducted the fire
> >drill training (i.e., Silverstein employees, Port Authority
> >employees, or a transition team representing both)?
> >2. Can you specify which floors in WTC 1 and WTC 2 were designated as
> >re-entry?
> >3. The emergency procedures manual cited a 3 day warning of an
> >impending fire drill; a previous communication from Saroj cited a
> >two-week written notice. Was practice somewhat longer than the written policy?
> >4. Our interpretation of the deputy floor warden is that they act as
> >a back-up floor warden, and otherwise a searcher. Is this correct?
> >5. The floor warden training video indicates that the Fire Safety
> >Director informs the floor warden which stairwell to use, while the
> >emergency procedures manual says that the floor warden tells the Fire
> >Safety director which stairwell the occupants are using. Is this
> >simply a matter of each keeping the other informed?
> >

> >Thanks,
> >
> >Jason
> >
> >Note: This document is a confidential and pre-decisional
> >communication
> >
> >Jason D. Averill
> >Fire Protection Engineer
> >Building and Fire Research Laboratory National Institute of Standards
> >and Technology
>
>
>=====

>Dr. S. Shyam Sunder
>Acting Deputy Director
>Building and Fire Research Laboratory
>National Institute of Standards and Technology Gaithersburg, MD
>20899-8600
>Tel.: 301-975-6350; Fax: 301-975-4032
>=====

=====

Dr. S. Shyam Sunder
Acting Deputy Director
Building and Fire Research Laboratory
National Institute of Standards and Technology Gaithersburg, MD 20899-8600
Tel.: 301-975-6850; Fax: 301-975-4032
=====